
CASE STUDY

INDIVIDUAL TEMPERATURE CONTROL

TAMBLYN CONSULTING SERVICES AUGUST 2003 TEL: 416-226-6565

OFFICE WORKERS IN AMERICA



SALARY OF UNHAPPY WORKERS.

10,000,000 x \$35,000/YH = \$1,400,000,000/DAY

AVERAGE SICK DAYS BLAMED ON AIR CONDITIONING 2 / YR

COST OF UNHAPPY WORKERS

 $2 \times 1,400,000,000 = $2,800,000,000/YR$

QUESTION:

FOR \$2,800,000,000/YR IS IT WORTH TRYING HARDER TO DESIGN A BETTER AIR CONDITIONING SYSTEM

BUILDING QUALITY REVIEW FOR PUBLIC WORKS CANADA BY DECIMA RESEARCH

(IN ORDER)

- 1. HVAC
- 2. LIFE SAFETY
- 3. CLEANING
- 4. ELEVATORS
- 5. SECURITY


LOWEST SATISFACTION LEVELS

- 1. HVAC
- 2. TENANT NEWSLETTER
- 3. PARKING SECURITY
- 4. LUNCH ROOM SERVICE
- 5. LOBBY APPEARANCE
- 6. EMERGENCY PROCEDURE TRAINING


CAUSES OF DISSATISFACTION

- 1. LACK OF INDEPENDENT TEMPERATURE CONTROL
- 2. LACK OF AIR MOVEMENT CONTROL
- 3. LACK OF GOOD VENTILATION
- 4. CROWDING OF OFFICE SPACE


FORTHCOMING REDUCTION IN WORKSTATION SIZE



SPACE RENTAL \$2,000/YR




SPACE RENTAL \$1,440/YR



SPACE RENTAL \$980/YR

* SPACE RENTAL ASSUMED AT \$20/FT2/YR



PROPOSED BUILDING CONTROL SYSTEMS FOR INTELLIGENT BUILDING WITH HIGH DENSITY WORKSTATIONS


THE CASE FOR ZERO COMPLAINT IN AIR CONDITIONING SYSTEMS

FEBRUARY 2003


TAMBLYN CONSULTING SERVICES


MIXING SYSTEM

DISPLACEMENT SYSTEM





SCANDINAVIAN CONCEPT







DE LUX
INDIVIDUAL CONTROL
WITH RAISED FLOOR






ZERO COMPLAINT CONCEPT






CONVENTIONAL AIR DISTRIBUTION




ZERO COMPLAINT AIR DISTRIBUTION











OVERHEAD VAV





FIGURE 4 GRID MEASUREMENTS FOR IAN POWER'S OFFICE 0.05/23.9 0.03/23.9 0.03/24.4 0.05/23.9 0.05/23.9 0.05/24.4 0.05/23.9 0.05/23.9 0.06/23.9 0.05/24.4 0.05/23.9 0.10/23.9 0.06/23.9 0.05/23.9 0.07/23.9 0.03/23.9 1676 mm 0.015/23.9 0.03/23.9 0.06/23.9 0.10/23.9 0.03/23.9 0.10/23.9 0.06/23.9 0.04/23.3 0.13/23.9 0.10/23.9 0.06/23.3 0.20/23.9 0.15/23.9 0.10/23.9 0.05/23.3 0.08/23.9 1372 mm 0.10/23.9 0.02/23.9 0.02/23.9 0.05/23.3 0.05/23.9 0.09/23.9 0.04/23.9 0.10/23.3 0.03/23.9 0.05/23.9 0.20/23.3 0.08/23.3 (0.05/23.9 0.02/23.9 0.10/23.3 0.15/23.3 1067 mm 0.04/23.3 0.04/23.3 0.06/23.3 0.06/23.3 0.02/23.3 0.04/23.3 0.03/23.3 0.05/23.3 0.02/23.3 0.05/23.3 0.10/23.3 0.15/22.8 0.04/23.3 0.07/23.3 0.03/22.8 0.08/22.8 762 mm 0.05/22.8 0.02/22.8 0.11/22.8 0.18/22.8 0.10/22.8 0.15/22.8 0.05/22.8 0.10/22.8 0.05/22.8 0.05/22.8 0.25/22.8 457 mm 0.10/22.8 0.02/22.2 0.15/22.8 0.23/22.2 0.25/22.8 0.15/22.8 0.25/22.8 0.12/22.2 0.30/22.8 0.15/22.8 0.15/22.8 0.23/22.2 150 mm 0.15/22.8 0.15/22.8 \$-\$5/\$\$-\$ - upwards velocity (rs/s) / temperature (C) #### mm = height above floor

ZERO COMPLAINT



AIR TERMINALS


22 PERIMETER AVERAGE 520 CFM 6 INTERIOR AVERAGE 1450 CFM TOTAL 19,700 CFM

TYPICAL HVAC LAYOUT FOR VAV CONTROL

AIR OUTLETS

44 PERIMETER AVERAGE 250 CFM 35 INTERIOR AVERAGE 250 CFM

TOTAL 19,700 CFM




AREA

PERIMETER 4,700 ft 2 INTERIOR 15,100 ft 2 CORE 1,800 ft 2 TOTAL 21,600 ft 2

HVAC LAYOUT FOR INDIVIDUAL CONTROL

AIR OUTLETS

36 PERIMETER AVERAGE 325 CFM 64 INTERIOR AVERAGE 125 CFM TOTAL 19,700 CFM



Cost of Typical System Sheetmetal 10,937 lbs x 1.1 [for waste] x \$3.50/lb Flex Duct 80 conn's x 8 ft x \$2.25/ft Light Troffers 80 x \$45.00

DDC Thermostat Control 28 x \$560.00

	¥ 2,
Light Troffers 80 x \$45.00	\$ 3,600
Install Light Troffers 80 x \$35	\$ 2,800
V AV Terminals 22 @ 750 CFM x \$250.00 6 @ 1500 CFM x \$325.00	\$ 5,500 \$ 1,950
Install V AV Terminals 28 x \$180	\$ 5,000
Profit and Tax on Equipment \$12,490 x 0.25	\$3,100

Cost of Air Jet System

Sheetmetal 8,270 lbs x 1.1 [for waste] x \$3.50/lb	\$31,800
Acoutiflex Duct 100 comn's x 10 ft x \$3.00/ft	\$ 3,000
Cone Fittings 100 x \$25.00	\$ 2,500
Auto Dampers with 1/60/24 motors 100 x \$75	\$ 7,500
Air Jet Platforms 100 x \$75	\$ 7,500
Thermostats and Transformers 100 x \$225	\$ 22,500
Profit and Tax on Equipment \$43,000 x 0.5	\$ 21,500
Wiring 100 x \$110	\$ 11,000
Total	\$107,300

Premium for Jet System

\$26,100

\$1.21/ft2 of floor area

\$261/person

0.75% of \$35,000/yr salary

COST COMPARISON OF VAV SYSTEMS

\$42,100


\$ 1,450

\$15,700


\$81,200

Total






HEAD ACHE



TROUBLE STAYING AWAKE



DRY OR IRRITATED THROAT





FIGURE 10



INTERVENTION FLOOR

CONTROL FLOOR

NOTE

HATCHED AREAS SHOW PERCENTAGE ATTRIBUTED TO THE BUILDING ENVIRONMENT. 17. PLEASE RATE HOW MUCH CONTROL YOU HAVE OVER YOUR ENVIRONMENT: CIRCLE ONE

NO PERSONAL CONTROL

0 1 2 3 4 5 6 7

FULL PERSONAL CONTROL

18. PLEASE RATE HOW MUCH YOU THINK THE HVAC CONDITIONS AT WORK INFLUENCE YOUR PRODUCTIVITY?

Decreased Productivity by

Increased Productivity by

30%

20%

10%


NO EFFECT

10%


20%


30%

PRODUCTIVITY LOSS BECAUSE OF HVAC



POTENTIAL FOR ENERGY SAVINGS WITH INDIVIDUAL CONTROL






ENHANCEMENT FOR ZERO COMPLAINT SYSTEM PART I

9993/02/WORK11b


PAYBACK SCENARIO FOR INDIVIDUAL CONTROL

ASSUMPTIONS

OCCUPANT SALARYOCCUPANT SPACE	
LIGHTING	1 WATT/FT 2
COMPARTMENT FAN	1 WATT/FT ²
COMPUTER SCREEN	100 WATTS
TENANT ELECTRICAL LOAD	2 WATT/FT ²
OUTSIDE AIR	30 CFM/PERSON
COOLING LOAD PER OCCUPANT	. @ 500 FT ² /ГОN = 0.4 TONS
FULL LOAD COOLING EQUIV. HRS	2,200 HRS/YR
OPERATING TIME FOR LIGHTS/FANS	5,000 HRS/YR
COST OF REFRIGERATION GYGLE	
COST OF ELECTRICITY	10 ¢ к₩Н



POTENTIAL ENERGY SAVINGS FOR ZERO COMPLAINT \$125 / YR





PREMIUM COST OF INDIVIDUAL CONTROL

PAYOUT SCHEDULE


MPROVEMENT	TIME
0%	2.4 YRS
1.7%	1YR
10%	42 DAYS


M23/02/983_US





ZERO COMPLAINT SYSTEM COMPUTER SCREEN





COMFORT CONTROL PANEL